

FITNESS CERTIFICATE

(To be filled by the Inspecting Officer)
(Junior Engineer)

1. Name of the Officer : **K. Radhakrishnan Nair, B.Sc. Engg., M.I.E., F.I.V.,**
Executive Engineer (Rtd), Irrign. Dept., Govt. of Kerala
2. Name of School : **ST. KURIAKOSE CBSE SENIOR SECONDARY**
SCHOOL, Thiruvampady, Neezhoor, Kaduthuruthy,
Kottayam District.
3. Location with name of Education : Thiruvampady, Neezhoor, Kaduthuruthy, in Vaikom Sub
Dist./Sub. Dist. District and Kaduthuruthy Education District.
4. Classification of building as specified : RCC framed structure with RCC foundation, columns, beams
in column 4 of the application for and slabs. Walls are with laterate / cement concrete block
fitness certificate and size masonry.
5. Period for which this certificate is : **16.10.2016 to 15.10.2017.**
issued
6. Name of defect if any : No defect.
 - a) Foundation and basement : RCC foundation and basement with RR masonry.
 - b) Superstructure : Superstructure with laterate / cement block masonry.
 - c) Doors/windows : Wooden doors / windows.
 - d) Wood work wrought and put up : Good quality wood.
 - e) Roof : Roofing with RCC slab / asbestos sheet roof
Flooring : Cement plastered / mosaic flooring
 - f) Miscellaneous (Crack etc.) : No crack / defect
7. Any major defect noticed which will : No major defect noticed.
render the building unsafe in any
manner
8. Whether maintenance work have : Yes.
been done
9. Whether the structure is sound or not : Structure is sound for conducting classes.

Note : 1. The stability of the structure should be examined also with reference to location,
altitude, intensity of wind, exposure to flood etc.
2. Any additional observations, if deemed necessary for certificate, may be furnished
separately with certificate.


Plinth area of this school building (Nos.IX/265A, B, C, D & E of Neezhoor Grama Panchayath)

Building with RCC roof (GF, FF, SF & TF) = 5587.76 sq.Mts. (60,124 sq.ft.)
Building with asbestos sheet roof = 2948.01 sq.Mts. (31,720 sq.ft.)

Certified that the school was inspected by me on **15.10.2016** and found to be fit to conduct
classes for the period from **16.10.2016 to 15.10.2017** for the reasons stated above.

Place : Tripunithura
Date : 16.10.2016

Signature
Designation


K. RADHAKRISHNAN NAIR, B.Sc., Engg.
Executive Engineer (Rtd.)
Irrigation Department
"Shreyas", Main Road
Tripunithura-682 301